


Inductive sensor

NCN3-F31K-N4-V1-V1

- Direct mounting on standard actuators
- Fixed setting
- EC-Type Examination Certificate TÜV99 ATEX 1479X
- Usable up to SIL 2 acc. to IEC 61508
- LEDs for switching state of sensor and solenoid valve
- Valve LEDs disconnectable

Dimensions



Technical Data

General specifications		
Switching function		2 x normally closed (NC)
Output type		NAMUR
Rated operating distance	s_n	3 mm
Installation		flush mountable
Assured operating distance	s_a	0 ... 2.4 mm
Actual operating distance	s_r	2.7 ... 3.3 mm typ.
Actuating element		Stainless steel 1.4305 / AISI 303 8.5 mm x 8.5 mm x 0.5 mm

Release date: 2020-06-10 Date of issue: 2020-06-10 Filename: 222682_eng.pdf

Technical Data

Reduction factor r_{Al}		0.5
Reduction factor r_{Cu}		0.4
Reduction factor r_{304}		1
Reduction factor r_{St37}		1.3
Reduction factor r_{Brass}		0.6
Output type		2-wire
Nominal ratings		
Nominal voltage	U_o	8 V
Switching frequency	f	0 ... 3 kHz
Hysteresis	H	typ. 5 %
Reverse polarity protection		reverse polarity protected
Short-circuit protection		yes
Suitable for 2:1 technology		yes , Reverse polarity protection diode not required
Current consumption		
Measuring plate not detected		≥ 3 mA
Measuring plate detected		≤ 1 mA
Time delay before availability	t_v	≤ 1.1 ms
Switching state indicator		LED, yellow
Valve status indicator		LED, yellow
Functional safety related parameters		
Safety Integrity Level (SIL)		SIL 2
$MTTF_d$		1470 a
Mission Time (T_M)		20 a
Diagnostic Coverage (DC)		0 %
Valve circuit		
Voltage		max. 32 V DC
Current		max. 240 mA
Short-circuit protection		no
Reverse polarity protection		yes, with reversed output LED is out of function, therfore more power for solenoid valve
Compliance with standards and directives		
Standard conformity		
NAMUR		EN 60947-5-6:2000 IEC 60947-5-6:1999
Electromagnetic compatibility		NE 21:2007
Standards		EN 60947-5-2:2007 EN 60947-5-2/A1:2012 IEC 60947-5-2:2007 IEC 60947-5-2 AMD 1:2012
Approvals and certificates		
EAC conformity		TR CU 012/2011
UL approval		cULus Listed, General Purpose
Ordinary Location		E87056
Hazardous Location		E501628
Control drawing		116-0456
CSA approval		cCSAus Listed, General Purpose
CCC approval		CCC approval / marking not required for products rated ≤36 V
Ambient conditions		
Ambient temperature		-25 ... 100 °C (-13 ... 212 °F)
Storage temperature		-40 ... 100 °C (-40 ... 212 °F)
Mechanical specifications		
Connection (system side)		Cage tension spring terminals
Core cross-section (system side)		Flexible: 0.2 ... 1.5 mm^2 rigid: 0.2 ... 2.5 mm^2
Connection (valve side)		4-pin, M12 x 1 socket
Housing material		PBT


Release date: 2020-06-10 Date of issue: 2020-06-10 Filename: 222682_eng.pdf

Technical Data


Sensing face	PBT
Degree of protection	IP67
Tightening torque, housing screws	1 Nm
Tightening torque, cable gland	M20 x 1.5 ; max. 7 Nm
Note	LED switch-off
General information	
Use in the hazardous area	see instruction manuals

Connection

N4-V1-V1



Connection Assignment



Wire colors in accordance with EN 60947-5-2

1	BN	(brown)
2	WH	(white)
3	BU	(blue)
4	BK	(black)
5	GY	(gray)

Matching system components

	**BT115A**	Activator for F31 series
	**BT115X**	Activator for F31 series

Accessories

	**VMBI-2+P/Z2-0,3M-PVC-V1-W-Y**	Valve connector, Form B (Ind) on M12, 2+PE, LED, Z diode, PVC cable

Release date: 2020-06-10 Date of issue: 2020-06-10 Filename: 222682_eng.pdf

Accessories

	**VMB-2+P/Z2-0,3M-PVC-V1-W-Y**	Valve connector, Form B on M12, 2+PE, LED, Z diode, PVC cable
	**VMA-2+P/Z2-0,3M-PVC-V1-W-Y**	Valve connector, Form A on M12, 2+PE, LED, Z diode, PVC cable
	**BT65B**	Activator for F31 series
	**BT115B**	Activator for F31 series
	**BT65A**	Activator for F31 series
	**BT65X**	Activator for F31 series

Release date: 2020-06-10 Date of issue: 2020-06-10 Filename: 222682_eng.pdf

Installation

Note

The connections to this sensor are sealed with stopping plugs to protect against dirt and moisture. If not all of the connections are used in your application, then seal the remaining stopping plugs on the sensor permanently or check during initial installation and when performing regular maintenance work that the stopping plugs are secure and impermeable. If necessary, tighten the stopping plugs to a torque of 1 Nm.

Release date: 2020-06-10 Date of issue: 2020-06-10 Filename: 222682_eng.pdf